

EXIDE
INDUSTRIAL

 **EXIDE**
INVA  **QUEEN**

The ^{QUEEN} Queen of
Inverter Batteries



Mera Inverter Maange Only **INVA**

INVAQUEEN 500 has rugged internal elements required for withstanding frequent and long power cuts. It is housed in a light-weight, durable, beautiful polypropylene container making it the Queen of all Inverter batteries. You can proudly display it in your living room. The thick plates ensure a long life and its through partition inter-cell connections ensure an even better voltage profile on discharge. The result : a steady discharge during powercuts of long duration and also enhanced service life. Moreover, it has got flat terminals and electrolyte level indicators, making INVAQUEEN a truly user-friendly inverter battery.

ADVANTAGES

- Better thermal management
- Customised exclusively for inverters
- Expected life – 2 years plus – under arduous conditions
- Easy maintenance
- Special glass mat bonded polythelene separator reduces the probability of internal short circuit, thus enhancing the service life

TECHNICAL SPECIFICATION

Model	Capacity*	Dimension (+/-3mm)			Weight (Kg +/-5%)		Volume of Electrolyte (1.220 Sp. Gr) Liters/Cell	Initial charge Minimum AH input (AH)	Initial Charge at Constant Current (A)		Constant Potential Limiting Current (Amps)	Trickle Charge (Current in mA)	
		Length	Width	Height*	Dry	Filled			Start (upto 2.36 vpc)	Finish (upto 2.75 vpc)		Min.	Max.
INVAQUEEN 500	150Ah	506	220	257	32.50	47.10	2.00	440	15.00	7.50	25	125	500

*The height mentioned is upto terminal top. *At 27°C when discharged at C20 upto 1.75 vpc (1.280 sp. gr).

HIGHER DISCHARGE RATES (OPTIONAL)

Hours	10	5	3	1	
Capacity in Ah	INVAQUEEN500	125	110	97	72

INITIAL CHARGING INSTRUCTIONS

1. Filling in Specific Gravity	1.220 +/- 0.005 at 27°C	5. Conditions of fully charged	a) 3 consecutive hourly readings of specific gravity and voltage become constant b) Top of charge voltage will be around 16.2V – 16.5V c) All cells should gas freely d) Minimum Ah has been given
2. Rest Period	4 - 6 hrs.		
3. Minimum Ah input	440Ah		
4. In order to reduce the charging time, the following routine may be adopted. For INVAQUEEN 500, the initial charging current may be 15.0A upto 2.36vpc followed by 7.5A upto 2.75vpc. However, in both cases, minimum Ah input to be given. Under no circumstances, battery temperature should exceed 50°C. In case the temperature exceeds 50°C, adequate rest to be given till the electrolyte temp. comes to ambient temp. and charging to be continued.			
6. Specific Gravity at fully charged condition	1.250 +/- 0.005 at 27°C		

NORMAL RECHARGING INSTRUCTIONS

Recharging through Inverter at constant potential mode of 14.4V with limited current as specified. After battery potential reaches 14.4V, the battery should continue in float charge mode at constant potential of 13.8V.

BATTERY SELECTION CHART

Inverter Rating VA	DC input voltage	Back-Up Duration						
		6 Hrs.	5 Hrs.	4 Hrs.	3 Hrs.	2 Hrs.	1 Hr.	
300	12	2P IQ500	1Q500	1Q500	1Q500	1Q500	1Q500	
500	12	2P IQ500	2P IQ500	2P IQ500	2P IQ500	2P IQ500	1Q500	
	24	2S IQ500	2S IQ500	2S IQ500	2S IQ500	2S IQ500	2S IQ500	
700	12	3P IQ500	3P IQ500	2P IQ500	2P IQ500	2P IQ500	1Q500	
	24	2S X 2P IQ500	2S X 2P IQ500	2S IQ500	2S IQ500	2S IQ500	2S IQ500	
1000	12	4P IQ500	4P IQ500	3P IQ500	2P IQ500	2P IQ500	1Q500	
	24	2S X 2P IQ500	2S X 2P IQ500	2S X 2P IQ500	2S IQ500	2S IQ500	2S IQ500	
1300	24	2S X 3P IQ500	2S X 2P IQ500	2S X 2P IQ500	2S X 2P IQ500	2S IQ500	2S IQ500	
	48	4S X 2P IQ500	4S IQ500	4S IQ500	4S IQ500	4S IQ500	4S IQ500	
2000	48	4S X 2P IQ500	4S X 2P IQ500	4S X 2P IQ500	4S X 2P IQ500	4S IQ500	4S IQ500	

S= Series connection; P= Parallel connection. 4S X 2P IQ500 => A string containing 4 nos. IQ500 batteries in series and 2 nos. such strings in parallel. IQ500 stands for INVAQUEEN500

Statutory Notice:

All batteries contain lead, which is harmful for humans and environment. As per statutory requirements, the used battery must be returned to the authorized dealer, manufacturer or at the designated collection centres.

Contact our Exide Powercentre Showrooms for Sales & Services



INVAQUEEN is a product of ISO 9001 and ISO 14001 certified factories

Head Office
Kolkata 'Exide House', 59E Chowringhee Road, Kolkata - 700 020, Phone (033) 2283 2120/33/36/50/51/71/ 2238/39, Fax (033) 2283 2632/37

Corporate Marketing Office
Kolkata 6A Hatibagan Road, Entally, Kolkata - 700 014, Phone (033) 2286 6158/6159, Fax (033) 2286 6186, E-mail: indicare@ent.exide.co.in

Regional Offices
New Delhi 'Exide House', 3E/1 Link Road, Jhandewalan Extension, New Delhi - 110 055, Phone (011) 2362 7095/ 96/98, 5154 0626, Fax (011) 2355 5703

Chennai 21/22, Alandur Road, Guindy, Chennai - 600 032, Phone (044) 2234 7326, 2231 6725 (Direct)/26, Fax (044) 2231 1216

Mumbai 'RAHEJAS', 5th Floor, 8C Main Avenue, V P Road, Santacruz (West), Mumbai - 400 054, Phone (022) 2646 5283/84, Fax (022) 2646 5042

Kolkata 6A Hatibagan Road, Entally, Kolkata - 700 014, Phone (033) 2284 3137, 2286 1860/6193 Fax (033) 2289 7455

Branch Offices
Bhubaneswar Phone (0674) 243 1385/1847, Fax (0674) 243 1385

Guwahati Phone (0361) 234 2500/1119

Jamshedpur Phone (0657) 242 6847/8349

Patna Phone (0612) 222 6632, 221 1040, 257 3039, Fax (0612) 223 1569

Siliguri Phone (0353) 254 0321

Chandigarh Phone (0172) 500 0014, 265 7409/4387/4553, Fax (0172) 265 4395

Ghaziabad Phone (0575) 273 4574, 283 2172/73

Jalpuri Phone (0141) 229 3704/3799, Fax (0141) 229 2877

Jalandhar Phone (0181) 553 4983, 223 7870, 223 7874, Fax (0181) 245 9571

Lucknow Phone (0522) 223 1255, 262 0722/6971, 261 5280, Fax (0522) 261 8089

Varanasi Phone (0542) 250 1680, Fax (0542) 250 1296 PP

Bangalore Phone (080) 5128 3492-5/2357 8672, Fax (080) 559 9624

Coimbatore Phone (0422) 222 1846, Fax (0422) 222 1737

Hyderabad Phone (040) 5516 3958 (D), 5569 6633

Kochi Phone (0484) 240 9128 (D), Fax (0484) 253 7869

Ahmedabad Phone (079) 2685 6697 (D)/8/9661, Fax (079) 2685 6698

Indore Phone (0731) 255 6290/91, Fax (0731) 249 3395

Mumbai Phone (022) 2646 5041, Fax (022) 2646 5042

Nagpur Phone (0712) 259 4722, 561 5882/83, Fax (0712) 259 1479

Pune Phone (020) 3230 4043 (D)/41/42, Fax (020) 2422 3843

Vadodara Telefax (0265) 235 4240

This catalogue is issued to provide outline information only and is not deemed to form part of an offer or contract. Our policy is one of continued improvement and we reserve the right to change details without prior notice.

PHV/IQ500/10K/08-2006

*Applied for

www.exideindustries.com